



ANDHRA UNIVERSITY COLLEGE OF ENGINEERING(A)
DEPARTMENT OF CIVIL ENGINEERING
VISAKHAPATNAM – 530 003
Mobiles: 9849100310, 9703335288

Dr.K.Rajasekhar

25-03-2021


STRUCTURAL SOUNDNESS CERTIFICATE

Subject: Study of Structural stability and soundness of SR Digi School, Hindustan Zinc Smelter Post, Near Gajuwaka, Visakhapatnam.


Ref: Letter from Principal , SR Digi School, Hindustan Zinc Smelter Post, Near Gajuwaka, Visakhapatnam, dated 24-03-2021.

This has been with respect to structural soundness of SR Digi School, Hindustan Zinc Smelter Post, Near Gajuwaka, Visakhapatnam managed by Sarvahitha Educational Society, Visakhapatnam . I have inspected the school building on 24-03-2021 for its stability and soundness. School is a masonry structure with G + 1 floor as per plan submitted by the party. School is running in the half the portion of ground floor and entire portion of first floor of the building. Structural drawings for the said structure are not made available during visit. It is reported by the principal that the existing building was constructed in the year 1998 and it is about 22 years old.

Adequate stair case facilities are provided in the building. As school building is concerned, all the visible elements of the building such as beams, slabs and brick work are found to be in good condition. There is no visible distress anywhere in the structural components of the building. In the present condition, this SR Digi School building, Hindustan Zinc Smelter Post, Near Gajuwaka, is structurally stable and sound to take care of the loads. However, proper maintenance is to be extended continuously. The validity of the certificate is for a period of two years from the date of issue of the certificate.


(K.RAJASEKHAR)

Forwarded to the client


(T.V.PRAVEEN)
Head of the Department
Department of Civil Engineering
College of Engineering (A)
Andhra University, Visakhapatnam